



Mahapalika Assistant Commissioner
Aundh - Baner Regional Office
Pune Municipal Corporation
Outward No:- 4657
Date :- 30/09/2022

Dr. Kalmadi Shamrao Highschool
Sr. No. 147/8+9+10,
Parthmesh Park, Marina road,
Near Jupiter Hospital,
Baner, Pune 45



Topic :- Certificate for Hygiene and safe measures of drinking water.
Reference:- Letter Number 7368, Dated: 27/09/2022

In reference on the above topic, we visited your school on 30/09/2022 to inspect and observed the Hygiene and safety measures of mineral water and corporation drinking water.

In the school premises the tap connection is done by Pune Municipal Corporation where the water gets stored in tank gets filtered through machine and then used for drinking purpose.

The AMC is done by Aqua Filter Technology. Drinking water is available on all the floors of the school.

All the reports from Water Supply department and Aqua Filter Technology are verified. Correct, and maintained.

By observing on all the above record. we hereby grant certificate for the purpose of mineral water facility in the school.

(Nitin Lokhande)
Health Inspector
Aundh - Baner Regional Office
Pune Municipal Corporation

(Jalindar Chandgude)
Senior Health Inspector
Aundh - Baner Regional Office
Pune Municipal Corporation



PUNE MUNICIPAL CORPORATION

Date : 21/03/2022

Parvati Water Works Laboratory

Report of Water Samples Collected as on 17/03/2022

Challan No : 12425-

Challan Date : 17/03/2022

Amount (Rs.): 1620.0

पुणे महानगरपालिका
Report ID: CH-15
पर्वती जलकेंद्र पुणे ३०
जावक क्र. - Lab NO -CH-15
दिनांक - 21/03/2022

मालकाचे नाव : डॉ.कलमाडी शामराव हायस्कूल

1) डॉ.कलमाडी शामराव हायस्कूल, सर्वे नं. १४७/८+९+१०, पार्क मरीना रोड ज्युपिटर हॉस्पिटल जवळ, मोजे बाणेर पुणे येथिल पिण्याच्या पाण्याचा नमुना.

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	7.25	Between 6.5 To 8.5	No Relaxation	-
Turbidity	1.0	Max 1	Max 5	N.T.U
Total Hardness (as CaCO ₃)	28.0	Max 200	Max 600	PPM
Chlorides (as Cl)	15.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	24.0	Max 200	Max 600	PPM
Nitrate-Nitrogen (as NO ₃)	0.3	Max 45	No relaxation	PPM
Nitrite Nitrogen (as NO ₂)	0.02	-	-	PPM
Coliform.	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	0.4	0.2	-	PPM

Remark : सदरचा नमुना / नमुने मालकांनी स्वतः आणून दिला. उपरोक्त नमुना / नमुने हा प्रातिनिधिक असल्याचे गृहीत धरले आहे. सदरचा अहवाल हा वैयक्तिक माहितीसाठी असून, याचा वापर कुठल्याही प्रकारचा परवान्यासाठी केल्याने उद्भवणाऱ्या कायदेशीर बाबींस हे कार्यालय जबाबदार असणार नाही. तसेच नमुनांच्या उद्दगमाविषयीचा पडताळा ह्या कार्यालयामार्फत केलेला नाही.


शेरा :

वरील नमुना क्र १ मधील पाणी पिण्यास योग्य आहे

(Mandar Sardeshpande)

केमिस्ट
पर्वती जलकेंद्र
पुणे महानगरपालिका
(Mob - 9689931937)

केमिस्ट
पर्वती जलकेंद्र
पुणे महानगरपालिका
21/03/2022



Date : 21/03/2022

PUNE MUNICIPAL CORPORATION

Report ID : CH15

Parvati Water Works Laboratory

Report of Water Samples Collected as on 17/03/2022

Challan No. : 12425- Challan Date : 17/03/2022 Amount (Rs.) : 1620.00

Owners Name : Dr. Kalmadi Shamrao High School

Pune Municipal Corporation
Parvati Water Treatment Plant
Javak No. Lab No. CH-15
Dtd. : 21/03/2022

1. Sample of drinking water supplied at Dr Kalmadi Shamrao Highschool Survey no 147/8+9+10. Park Marina, Near Jupiter Hospital at post Baner Pune

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	7.25	Between 6.5 To 8.5	No Relaxation	-
Turbidity	1.0	Max 1	Max 5	N.T.U
Total Hardness (as CaCO ₃)	28.0	Max 200	Max 600	PPM
Chlorides (as Cl)	15.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	24.0	Max 200	Max 600	PPM
Nitrate Nitrogen (as NO ₃)	0.3	Max 45	No relaxation	PPM
Nitrate Nitrogen (as NO ₂)	0.02	-	-	PPM
Coliform	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	0.4	0.2	-	PPM

Remark: The present sample/samples was/were brought by owner. This sample is considered in representative capacity. This report is issued for the personal records of owner. This office will not be held responsible for any legal disputes regarding the licenses obtained based on this report. Verification of source of sample is not done by this office.

Remark: The water samples no 1 cited above is suitable for drinking.

Signed and sealed by
Chemist
Parvati Water Treatment Plant
Pune Municipal Corporation



PRINCIPAL
DR. KALMADI SHAMARAO HIGH SCHOOL
BANER BRANCH

Translated as per original

V B Deshmukh

VIKRAM B. DESHMUKH
ADVOCATE, PUNE
Reg.No. MAH/2149/1999

ATTESTED

MRS. MEERA N. GAWARE
NOTARY GOVT. OF INDIA
PUNE.



Mahapalika Assistant Commissioner
Aundh - Baner Regional Office
Pune Municipal Corporation
Outward No:- 4658
Date :- 30/9/2022

Dr. Kalmadi Shamrao Highschool
Sr. No. 147/8+9+10,
Parthmesh Park, Marina road,
Near Jupiter Hospital,
Baner, Pune 45



Topic :- Certificate for Hygiene and safe measures of washrooms.
Reference:- Letter Number 7367, Dated: 27/09/2022

In reference on the above topic, we visited your school on 30/09/2022 to inspect and observed the Hygiene and safety measures. There are in the school and below is the observation.

Details	Gents Toilet	Ladies Toilet	Gents Urinal	Boys Toilet	Boys Urinal	Girls Toilet	Boys Kids Toilet	Boys Kids Toilet	Girls Kids Toilet	Handicap
Ground Floor	1	2	1	2	8	4	4	-	5	-
1St Floor	1	1	-	2	8	4	-	7	5	1
2nd Floor	-	-	-	2	8	4	-	-	-	-
3rd Floor	-	-	-	2	8	4	-	-	-	1
4th Floor	-	-	-	2	8	4	-	-	-	-
5 th Floor	-	-	-	1	-	1	-	-	-	-

As per the table on every floor there are washrooms and toilet.

On every floor water, light facility is available. For cleanliness acid, phenyl and liquid of good quality are kept in every washroom. In the same way boards like Boy's, Girls, Gents and Ladies are shown on the toilet doors. Hooks, Napkins, and wash basin are there in every washroom. Wet garbage and Dry garbage are kept in separate Bags (Dustbin)

For Cleaning the toilet, the school has sufficient staff, and the work is done very efficiently.

On the above observation we have no objection in regards with Hygiene and safety measures which are taken in the school and we issue this certificate for the same.

(Nitin Lokhande)
Health Inspector
Aundh - Baner Regional Office
Pune Municipal Corporation

(Jalindar Chandgude)
Senior Health Inspector
Aundh - Baner Regional Office
Pune Municipal Corporation